

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE	PAGE OF PAGES 1 5	
2. AMENDMENT/MODIFICATION NO. A-001	3. EFFECTIVE DATE 9/25/2014	4. REQUISITION/PURCHASE REQ. NO. PR3714142	5. PROJECT NO. (If applicable)		
6. ISSUED BY Contracting & Procurement General Services Office, American Embassy Manila Seafront Compound, Roxas Boulevard, Pasay City		7. ADMINISTERED BY (If other than Item 6) CODE			
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State, and ZIP Code)			(√) X	9A. AMENDMENT OF SOLICITATION NO. SRP380-14-Q-0121	
				9B. DATED (SEE ITEM 11) 09/26/2014	
				10A. MODIFICATION OF CONTRACT/ORDER NO.	
				10B. DATED (SEE ITEM 13)	
FACILITY CODE					

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

☒ The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers ☒ --Is extended, ☐ is not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:

(a) By completing Items 8 and 15, and returning 1 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter of telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGEMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

(√)	A.	THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
	B.	THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b)
	C.	THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D.	OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor ☒ is not, ☐ is required to sign this document and return ___ copy to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

SRP380-14-Q-0121 is being amended as follows:

- Attached are the answers to the questions raised by the offerors.
- To include drawings and pictures as part of the solicitation
- The submission is extended from September 25, 2014 1:00 PM to September 26, 2014 1:00 PM
- All other terms and conditions remain unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type of print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or Print) JOHN KLIMOWSKI	
15B. CONTRACT/OFFEROR (Signature of person authorized to sign)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA (Signature of Contracting Officer)	16C. DATE SIGNED

Subject: SOLAR PANEL

The U.S. Embassy of Manila invites you to submit a quotation for the requirements below.

For the **Supply and Deliver** of the 10KW Grid- Tie Photovoltaic PV System which includes:

- 40 x 250W monocrystalline photovoltaic solar panels
- 40 microinverter, SMIN215R60MC, Siemen or approved equivalent
- 2 Microinverter cable, 208V 3P, ET1720830, Siemens or approved equivalent
- 10 light weight rail for solar panel modules
- 1 envoy communication gateway

**Document
Summary:**

General information:

- a. **No. of rows of solar panel : 4; no. of solar panel per row: 10; Total Solar Panels: 40**
- b. **Roof type is gable roof (with rain gutter on both longitudinal sides)**
- c. **The solar panels will be mounted to 13 pitch angle**
- d. **Roofing is mounted to metal Z-purlins and over metal double how truss type**
- e. **Roof trusses center to center distance is 5.5m.**
- f. **Attachment 1 & 2 drawings and pictures for your reference**

A
0
0
1

Note: You may suggest other brand or model equivalent. Subject to technical approval

Remarks:

Price offer shall be firm fixed-price, VAT exempt. The U.S. Government is exempt from paying the ad valorem/specific tax, customs and duties imposed by the Philippine Government under Section 106(a) and 109 of the Tax Code of 1997, respectively. Thus, price(s) shall be billed to the U.S. Government net of ad valorem tax, value added tax, customs and duties. Payment shall be made via Electronic Fund Transfer (EFT) within 30 days from receipt of the items ordered and the original copy of invoice. The Direct Deposit Sign Up Form for EFT payment will be provided to the vendor upon award. All items should be delivered to US Embassy Manila Seafront Compound, Pasay City. See attached document for further remarks, including applicable clauses.

The RFQ is valid until 1:00 PM , **26** September, 2014 (MANIL)

A
0
0
1

Instructions: You may submit your firm fixed price (Exclusive of VAT) through e-mail to LegayadaBB@state.gov or send through fax at +632 548-6762. For further queries, please get in touch with Ms. Dette Legayada at 301-2000 x 2975.

NOTE: All actions which are over \$25K, prospective vendors must be registered within the Central Contractor Registration (CCR) which is now under System for Award

Management (SAM). Refer to site for details on the registration process:

http://pd.statebuy.state.gov/content.asp?content_id=62&menu_id=60 (please see attachment)

Q&A for SRP38014Q0121

Q: What are the number of rows of solar panels and number of solar panels per row for the 10kW system?

A: Kindly refer to General information letter a.

Q: What is the roof type that the solar panels will mount to?

A: Please refer to General information letter b.

Q: What is the pitch(angle) of the roof that the solar panels will mount to




A: Please refer to General information letter c.

Q: What is the roof rafter type and dimensions for the roof that the solar panels will mount to?

A: Kindly refer to General information letter d.

Q: What is the roof rafter dimensions from center to center of the roof rafters for the roof the solar panels will mount to?

A: Please refer to General information letter e.



ATTACHMENT 2



IMAGE 1



IMAGE 2




IMAGE 3



IMAGE 4